



NOTES	
RECOMMENDED MINIMUM CLEARANCES	* FRONT:- 1000 m.m. * REAR:- 1000 m.m. * TOP:- 500 m.m. * SIDE:- 1000 m.m. * [MULTIPLE PANELS MAY BE STACKED SIDE BY SIDE]
RECOMMENDED OPERATING CONDITION	* AMBIENT TEMP:-45 deg.C max. * MAX.HUMIDITY:- 95% RH NON CONDENSING
COLOR	* OUTSIDE :- RAL-7032 * INSIDE :-RAL-7032 * METER PLATE :-BLACK
MATL.	* CRCA STEEL SHEET * FRAME:- 2.0 m.m.THK. * DOORS:- 2.00 & 1.6 m.m.THK.
DEGREE OF PROTECTION :- IP-41	
INPUT TERMINAL HEIGHT OF GND :- MINI.350 m.m.	

APPLICABLE TO
 → 100KVA & 120KVA SSVS

REV.	DESCRIPTION	DATE	APPRD.	DRN.	APPRD.	TITLE:-
				Jitu	Ajit	CONFIG OVER VIEW
		06.11.06	06.11.06	06.11.06	06.11.06	
				SHEET :- 01	OF 01	
				DRG.NO.	065C012100	
				REV.	0	
				ALL DIMENSIONS IN M.M. [NTS.]		
				DIR. REF :-ENGG-2/		
				HI-REL ELECTRONICS PVT.LTD.		
				UNIT-2,UPS & POWER CONDITIONING DIVISION		

REV RECORD