

1 2 3 4 5 6 7 8

| NOTES | |
|-----------------------------------------------|------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| RECOMMENDED MINIMUM CLEARANCES | <ul style="list-style-type: none"> * FRONT:- 1000 m.m. * REAR:- 1000 m.m. * TOP:- 500 m.m. * SIDE:- 1000 m.m. * [MULTIPLE PANELS MAY BE STACKED SIDE BY SIDE] |
| RECOMMENDED OPERATING CONDITION | <ul style="list-style-type: none"> * AMBIENT TEMP:-45 deg.C max. * MAX.HUMIDITY:- 95% RH NON CONDENSING |
| COLOUR | <ul style="list-style-type: none"> * OUTSIDE :- RAL-7032 * INSIDE :-RAL-7032 * METER PLATE :-BLACK |
| MATL. | <ul style="list-style-type: none"> * CRCA STEEL SHEET * FRAME:- 2.0 m.m.THK. * DOORS:- 2.00 & 1.6 m.m.THK. |
| DEGREE OF PROTECTION :- IP-41 | |
| INPUT TERMINAL HEIGHT OF GND :- MINI.350 m.m. | |



| REV. | DESCRIPTION | DATE | APPRD. | DRN. | APPRD. | TITLE:- |
|------|-------------|------|--------|-----------|----------|--------------------------------------------------------------|
| | | | | Jitu | JKS | CONFIG OVER VIEW FOR |
| | | | | 31.11.06 | 31.11.06 | |
| | | | | SHEET:-01 | OF 01 | DRG.NO. 065C012100 |
| | | | | | | REV. 0 |
| | | | | | | ALL DIMENSIONS IN M.M. [INTS.] DIR. REF :-ENGG-2/A-061113 |

HI-REL ELECTRONICS PVT.LTD.

UNIT-2,UPS & POWER CONDITIONING DIVISION

APPLICABLE TO

- 25KVA & 30KVA UPS
- 25KVA & 30KVA SCVS PANEL
- 25KVA & 30KVA SSVS PANEL

REV RECORD