

	NOTES
F	<ul style="list-style-type: none"> * FRONT:- 1000 m.m. * REAR:- 1000 m.m. * TOP:- 500 m.m. * SIDE:- 1000 m.m. * [MULTIPLE PANELS MAY BE STACKED SIDE BY SIDE]
E	<ul style="list-style-type: none"> * AMBIENT TEMP:-45 deg.C max. * MAX.HUMIDITY:- 95% RH NON CONDENSING
D	<ul style="list-style-type: none"> * OUTSIDE :- RAL-7032 * INSIDE :-RAL-7032 * METER PLATE :-BLACK * CRCA STEEL SHEET * FRAME:- 2.0 m.m.THK. * DOORS:- 2.00 & 1.6 m.m.THK.
C	DEGREE OF PROTECTION :- IP-41
B	INPUT TERMINAL HEIGHT OF GND :- MINI.150 m.m.
A	



APPLICABLE TO
→ 5KVA & 10KVA UPS
→ 5KVA & 10KVA SCVS PANEL

REV.	DESCRIPTION	DATE	APPRD.	DRN.	APPRD.	TITLE:-
				Jitu	Ajit	CONFIG OVER VIEW FOR
				23.04.07	23.04.07	0 6 5 C 0 A L I 0 0
				SHEET:- 01	01	DRG.NO.
				0	0	REV.
						ALL DIMENSIONS IN MM. [INTS.] DIR. REF :-ENGG-2/A-0610114
HI-REL ELECTRONICS PVT.LTD.						
UNIT-2,UPS & POWER CONDITIONING DIVISION						

REV.RECORD